

- The frequency of the digital filter for inputs X0~X7 of the MA main unit may have 4 choices from 4K/8K/16K/32KHz.
- When the communication port 1 or port 2 of the MC main unit has been set working in the slave mode of Modbus RTU communication protocol, or by using the FUN150 instruction to let the PLC work in the master mode of Modbus RTU communication protocol, the data bit of communication parameter of the corresponding port will be set with 8-bit automatically.
- Improve the undesired reading value of the extended temperature or analog input module that may occur in OS version V3.72 .